



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Medway Middle School
25 Middle School Drive
Medway, ME 04460

Date Printed: 07/06/2022
Work Order #: 2205-01676
Client Job #: 295
Date Received: 05/11/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**


SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 07/06/2022
CLIENT NAME: Medway Middle School

CLIENT ADDRESS: 25 Middle School Drive
Medway, ME 04460

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 05/11/2022 09:25AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 20° CELSIUS
CLIENT JOB #: 295

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01676-001	3 Sink dishwasher room kitchen	I	KF	05/06/2022 06:43AM	1.8	ppb			DR-NH	06/29/2022 06:10PM
2205-01676-002	Sink dishwasher Room Kitchen	I	KF	05/06/2022 06:44AM	2.9	ppb			DR-NH	06/29/2022 06:13PM
2205-01676-003	Salad sink	I	KF	05/06/2022 06:41AM	3.7	ppb			DR-NH	06/29/2022 06:15PM
2205-01676-004	Hand sink	I	KF	05/06/2022 06:42AM	<1	ppb			DR-NH	06/29/2022 06:18PM
2205-01676-005	Boy's locker hand sink	I	OT	05/06/2022 06:58AM	4.1	ppb			DR-NH	06/29/2022 06:21PM
2205-01676-006	Girl's locker hand sink	I	OT	05/06/2022 07:01AM	1.8	ppb			DR-NH	06/29/2022 06:30PM
2205-01676-007	Kitchen Kettle	I	KF	05/06/2022 06:40AM	15.5	ppb			DR-NH	06/29/2022 06:33PM
2205-01676-008	Lobby water fountain	I	DWF	05/06/2022 06:46AM	<1	ppb			DR-NH	06/29/2022 06:36PM
2205-01676-009	5 th + 6 th grades hall water fountain	I	DWF	05/06/2022 06:46AM	<1	ppb			DR-NH	06/29/2022 06:45PM
2205-01676-010	7 th + 8th grades hall water fountain	I	DWF	05/06/2022 06:51AM	1.8	ppb			DR-NH	06/29/2022 06:48PM
2205-01676-011	Men's lobby bathroom sink	I	OT	05/06/2022 06:51AM	3.9	ppb			DR-NH	06/29/2022 06:51PM
2205-01676-012	Women's lobby bathroom sink	I	OT	05/06/2022 06:50AM	1.4	ppb			DR-NH	06/29/2022 06:54PM
2205-01676-013	Payroll office sink	I	OT	05/06/2022 06:34AM	9.3	ppb			DR-NH	06/29/2022 06:57PM
2205-01676-014	Teacher's room sink	I	OT	05/10/2022 05:11AM	3.9	ppb			DR-NH	06/29/2022 07:08PM
2205-01676-015	Art room sink	I	OT	05/06/2022 07:05AM	4.0	ppb			DR-NH	06/29/2022 07:11PM
2205-01676-016	Science room 111, 5 th + 6th grades	I	OT	05/06/2022 07:04AM	15.9	ppb			DR-NH	06/29/2022 07:14PM
2205-01676-017	Nurse's room sink	I	OT	05/06/2022 07:05AM	2.5	ppb			DR-NH	06/29/2022 07:17PM
2205-01676-018	Nurse's room bathroom sink	I	OT	05/06/2022 07:02AM	2.8	ppb			DR-NH	06/29/2022 07:20PM
2205-01676-019	Science room 103, 7th + 8th grades	I	OT	05/06/2022 07:08AM	17.6	ppb			DR-NH	06/29/2022 07:29PM
2205-01676-020	Boy's bathroom hand sink on right side	I	OT	05/06/2022 06:53AM	<1	ppb			DR-NH	06/29/2022 07:32PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 07/06/2022
CLIENT NAME: Medway Middle School
CLIENT ADDRESS: 25 Middle School Drive
 Medway, ME 04460
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 05/11/2022 09:25AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 20° CELSIUS
CLIENT JOB #: 295

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2205-01676-021	Boy's bathroom hand sink on left side	I	OT	05/06/2022 06:53AM	<1	ppb			DR-NH	06/29/2022 07:35PM
2205-01676-022	Girl's bathroom hand sink on left side	I	OT	05/06/2022 06:55AM	1.3	ppb			DR-NH	06/29/2022 07:44PM
2205-01676-023	Girl's bathroom hand sink on right side	I	OT	05/06/2022 06:54AM	1.7	ppb			DR-NH	06/29/2022 07:46PM
2205-01676-024	Ice maker Gym	I	OT	05/06/2022 07:10AM	<1	ppb			DR-NH	06/29/2022 07:49PM
2205-01676-025	Outside water spigot south side	I	OT	05/06/2022 07:20AM	236	ppb			DG-NH	07/05/2022 04:23PM
2205-01676-026	Outside water spigot north side	I	OT	05/06/2022 07:22AM	377	ppb			DG-NH	07/05/2022 04:27PM

Rebecca L. Labranche
 Laboratory Director